

**SUMMIT TOWNSHIP  
Erie County, PA**

**AMENDMENT TO**

**ORDINANCE No. 1994-01**

**Amended by  
ORDINANCE No. 1996-03**

**Amended by  
ORDINANCE No. 1999-02**

**Amended by  
ORDINANCE No. 2009-03**

**and**

**Amended by  
ORDINANCE No. 2016-04**

WHEREAS, Summit Township has adopted an Ordinance 1994-01 as most recently amended by Ordinance 2009-03 requiring that the improved properties in the Township of Summit, Erie County, Pennsylvania, be connected with the Public Sanitary Sewerage System; establishing standards for contributors into the wastewater collection and treatment system; determining purposes and policy and providing definitions and abbreviations; establishing regulations including general discharge prohibitions and specific pollutant limitations, federal categorical pretreatment standards and modifications thereof, State requirements and revision thereof, excessive and accidental discharges, employer notices and written reports; authorizing fees and charges; providing for administration including permits for wastewater contributions and discharges, reporting, monitoring, inspection and sampling requirements for pretreatment and requiring confidentiality of information; requiring enforcement including permit revocation, violation notices, show cause hearings and legal action for harmful contributions; and prescribing civil and criminal penalties for violations; and

WHEREAS, the City of Erie, as operator of the treatment plant, is required by the U.S. Environmental Protection Agency's "General Pretreatment Regulations" (40 C.F.R. 403) to control certain industrial discharges; and

WHEREAS, Summit Township desires to amend Ordinance 1994-01 as most recently amended by Ordinance 2009-03, in Section 2.4 to reflect updated local limits in order to be in compliance with applicable regulations of the City of Erie and United States Environmental Protection Agency

NOW, THEREFORE, be it enacted by the Township of Summit, Erie County, Pennsylvania, as follows:

Section 2.4 Local Limits.

The following pollutant limits are established to protect against pass through and interference. No person shall discharge wastewater containing in excess of the following instantaneous maximum allowable discharge limits:


| <u>Parameter</u> | <u>Limit</u> |
|------------------|--------------|
| Arsenic (As)     | 1.0 mg/l     |
| Cadmium (Cd)     | 0.6 mg/l     |
| Chromium (Cr)    | 8.0 mg/l     |
| Copper (Cu)      | 1.9 mg/l     |
| Cyanide (CN)     | 1.2 mg/l     |
| Lead (Pb)        | 0.8 mg/l     |
| Mercury (Hg)     | 0.0003 mg/l  |
| Nickel (Ni)      | 7.0 mg/l     |
| Silver (Ag)      | 1.9 mg/l     |
| Zinc (Zn)        | 3.4 mg/l     |
| Phosphorus (P)   | 23.4 mg/l    |
| Oil & Grease     | 250 mg/l     |
| pH               | 5.0/12.0     |

The above limits apply at the point where the wastewater is discharged to the POTW. All concentrations for metallic substances are for "total" metal unless indicated otherwise. The Superintendent may impose mass limitations in addition to, or in place of, the concentration-based limitations above.


12.3 Effective Date.

This ordinance shall become effective on SEPT. 6, 2016.


SUMMIT TOWNSHIP SUPERVISORS

  
Nancy Agostine, Chairperson

  
Jack F. Lee, Jr. Supervisor

  
Mark A. Welka, Supervisor

ATTEST:

  
Title: Administrative Secretary

# 1733357.v1